CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

CQCE/BBMP/NMK/017/2021-22

Date: 26.11.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Name of the work	: **Assistant Executive Engineer,** Yashwanthapura Sub Division, BBMP, **Sri. N M Krishnamurthy,** Contractor, Bangalore. :Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) Ambedkar Nagara (Ward No.37)
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	19.11.2021	26.11.2021	8.015	498.6	22.16
2	19.11.2021	26.11.2021	8.135	515.4	22.91
3	19.11.2021	26.11.2021	8.189	527.7	23.45

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

CQC/BBMP/NMK/017/2021-22

Date: 17.12.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Name of the work : **Assistant Executive Engineer,** Yashwanthapura Sub Division, BBMP, **Sri. N M Krishnamurthy,** Contractor, Bangalore.
:Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore

Sample ID : Cement Concrete

Location Near By Ex Council Mamatha House (Ward No.17) Ambedkar Nagara (Ward No.37)

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M30

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	19.11.2021	17.12.2021	8.101	722.2	32.10
2	19.11.2021	17.12.2021	8.077	733.3	32.59
3	19.11.2021	17.12.2021	8.021	744.4	33.08

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

VIL QUALITY
CONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited
Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

NCE/BBMP/NMK/017/2021-22

Date: 26.11.2021

EST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

ame of the work	: Assistant Executive Engineer, Yashwanthapura Sub Division, BBMP, Sri. N M Krishnamurthy, Contractor, Bangalore. :Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) Ambedkar Nagara (Ward No.37)
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	19.11.2021	26.11.2021	8.028	511.1	22.72
2	19.11.2021	26.11.2021	8.174	522.2	23.21
3	19.11.2021	26.11.2021	8.126	533.3	23.70

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

VIL QUALITY
ONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited
Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

CQC/BBMP/NMK/017/2021-22

Date: 17.12.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Name of the work	: **Assistant Executive Engineer,** Yashwanthapura Sub Division, BBMP, **Sri. N M Krishnamurthy,** Contractor, Bangalore. :Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) Ambedkar Nagara (Ward No.37)
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	19.11.2021	17.12.2021	8.063	722.2	32.10
2	19.11.2021	17.12.2021	8.167	736.5	32.73
3	19.11.2021	17.12.2021	8.141	745.4	33.13

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

IL QUALITY
ONSULTANTS & ENGINEERS
SO 9001:2015 Certified & NABL Accredited
Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

CC/BBMP/NMK/017/2021-22

Date: 27.11.2021

T-REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

ame of the work	: **Assistant Executive Engineer,** Yashwanthapura Sub Division, BBMP, **Sri. N M Krishnamurthy,** Contractor, Bangalore. :Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) B K Nagara 12th main, 12th Cross road in Front of Gangamma House
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	20.11.2021	27.11.2021	8.079	513.4	22.82
2	20.11.2021	27.11.2021	8.179	521.7	23.19
3	20.11.2021	27.11.2021	8.115	536.5	23.84

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Lab No.: CQCE/BBMP/NMK/017/2021-22

Date: 18.12.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: Assistant Executive Engineer, Yashwanthapura Sub Division, BBMP,
Agency	Sri. N M Krishnamurthy, Contractor, Bangalore.
Name of the work	:Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) B K Nagara 12th main, 12th Cross road in Front of Gangamma House
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	20.11.2021	18.12.2021	8.039	730.6	32.47
2	20.11.2021	18.12.2021	8.166	740.5	32.91
3	20.11.2021	18.12.2021	8.011	750.7	33.36

Note:

1. The Material is Satisfied as per the Requirement.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Report No.: CQCE/BBMP/NMK/017/2021-22

Date: 27.11.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: Assistant Executive Engineer, Yashwanthapura Sub Division, BBMP,
Agency	Sri. N M Krishnamurthy, Contractor, Bangalore.
Name of the work	:Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) B K Nagara 12th main, 12th Cross road in Front of Gangamma House
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	20.11.2021	27.11.2021	8.140	520.4	23.13
2	20.11.2021	27.11.2021	8.168	530.6	23.58
3	20.11.2021	27.11.2021	8.069	516.8	22.97

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Lab No.: CQCE/BBMP/NMK/017/2021-22

Date: 18.12.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client Agency	: Assistant Executive Engineer, Yashwanthapura Sub Division, BBMP,
Name of the work	Sri. N M Krishnamurthy, Contractor, Bangalore. :Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) B K Nagara 12th main, 12th Cross road in Front of Gangamma House
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	20.11.2021	18.12.2021	8.147	731.6	32.52
2	20.11.2021	18.12.2021	8.188	745.4	33.13
3	20.11.2021	18.12.2021	8.110	752.7	33.45

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Report No.: CQCE/BBMP/NMK/017/2021-22

Date: 27.11.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: Assistant Executive Engineer, Yashwanthapura Sub Division, BBMP,
Agency	Sri. N M Krishnamurthy, Contractor, Bangalore.
Name of the work	:Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) B K Nagara 12th main, 12th Cross road in Front of Gangamma House
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	20.11.2021	27.11.2021	8.048	524.7	23.32
2	20.11.2021	27.11.2021	8.099	536.9	23.86
3	20.11.2021	27.11.2021	8.192	518.8	23.06

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/NMK/017/2021-22

Date: 18.12.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: Assistant Executive Engineer, Yashwanthapura Sub Division, BBMP,
Agency	Sri. N M Krishnamurthy, Contractor, Bangalore.
Name of the work	:Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) B K Nagara 12th main, 12th Cross road in Front of Gangamma House
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	20.11.2021	18.12.2021	8.164	734.6	32.65
2	20.11.2021	18.12.2021	8.087	745.5	33.13
3	20.11.2021	18.12.2021	8.031	752.8	33.46

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/NMK/017/2021-22

Date: 27.11.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: Assistant Executive Engineer, Yashwanthapura Sub Division, BBMP,
Agency	Sri. N M Krishnamurthy, Contractor, Bangalore.
Name of the work	:Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashtayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) B K Nagara 12th main, 12th Cross road in Front of Gangamma House
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	20.11.2021	27.11.2021	8.043	526.4	23.40
2	20.11.2021	27.11.2021	8.125	536.7	23.85
3	20.11.2021	27.11.2021	8.185	519.3	23.08

Note:

1. The Material is Satisfied as per the Requirements

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/NMK/017/2021-22

Date: 18.12.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	
Agency	: **Assistant Executive Engineer,** Yashwanthapura Sub Division, BBMP,
Name of the work	**Sri. N M Krishnamurthy,** Contractor, Bangalore. :Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) B K Nagara 12th main, 12th Cross road in Front of Gangamma House
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	20.11.2021	18.12.2021	8.168	736.8	32.75
2	20.11.2021	18.12.2021	8.059	747.6	33.23
3	20.11.2021	18.12.2021	8.182	757.4	33.66

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/NMK/017/2021-22

Date: 27.11.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: **Assistant Executive Engineer,** Yashwanthapura Sub Division, BBMP,
Agency	**Sri. N M Krishnamurthy,** Contractor, Bangalore.
Name of the work	:Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) B K Nagara 12th main, 12th Cross road in Front of Gangamma House
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	20.11.2021	27.11.2021	8.076	521.6	23.18
2	20.11.2021	27.11.2021	8.199	532.4	23.66
3	20.11.2021	27.11.2021	8.095	539.5	23.98

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 056.
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS
ISO 9001:2015 Certified & NABL Accredited Laboratory as per ISO/IEC - 17025-2017

Testing of Construction Material - Mechanical, Soil, Bitumen, Non Destructive Testing Services, Project Management Consultants, Third Party Quality Assurance, DPR.

Job No.: CQCE/BBMP/NMK/017/2021-22

Date: 18.12.2021

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	: **Assistant Executive Engineer,** Yashwanthapura Sub Division, BBMP,
Agency	**Sri. N M Krishnamurthy,** Contractor, Bangalore.
Name of the work	:Comprehensive Development of Roads, Drains, Special repairs to buildings and other works in Sunnadagoodu, Ambedkarnagar, Mohan Kumar nagar, Poornapura, Ramabhovi Colony, Jalahalli Harijana, Siddarthanagar, Khathanagar, Ashrayanagar, Karadigudi, Peenya 4th block A K Colony and Surrounding areas of Slums in R R Nagar Constituency under PACKAGE-2019-20 RRN-DIV-(13). BBMP, Bangalore
Sample ID	: Cement Concrete
Location	Near By Ex Council Mamatha House (Ward No.17) B K Nagara 12th main, 12th Cross road in Front of Gangamma House
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M30
Compressive Strength as on	: 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	20.11.2021	18.12.2021	8.083	724.6	32.20
2	20.11.2021	18.12.2021	8.122	734.8	32.66
3	20.11.2021	18.12.2021	8.007	744.5	33.09

Note:

1. The Material is Satisfied as per the Requirements.

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Corporate Off.: No. 133, Bhuvaneshwarinagar, Doddabasti Main Road, Bangalore-560 05
Contact: 8553518550, 080-23240644 Email: civilqualityconsultants@gmail.com

Scanned with CamScanner